



WATER/WASTEWATER REPORT 3RD QUARTER 2023

Seems like everything is going smooth. Talked to Dan on 7/6/23 and he is making about 10,000 gallons/day when he is out. He has been reading meters and we are not sure if there is a leak or not. When I get last month's data, it will let us know for sure.

The WWTP pond is overrun with algae. I have a diffuser to install, which should help with the issue. Installation should be done by 8/4.

BFU had to reseed the WWTP twice last month. I have not heard why, so I am assuming the torrential rains.

No other issues to report.